

Appliance Testing Pass Certificate


Client Name	Eugene Portman	CERTIFICATE DATE: 23/11/2015
Address	Semper Fidelis	Wiremill Lane
	Newchapel	Lingfield Surrey
Location Name	Mobile Home	
	Lingfield	

TEST RESULTS

Test Date	Appliance	Description	Class/ Voltage	Visual		Earth	Continuity	Insulation	Load	Leak.	Flash
				Fuse	Cord						
21/11/1915	00000EUP01	IEC MAINS LEAD	1 240	P		0.07	P	S >9.90 P	S <0.05 P	<0.30 P	S
21/11/1915	00000EUP02	IEC MAINS LEAD	1 240	P		0.12	P	S >9.90 P	S <0.05 P	<0.30 P	S
21/11/1915	00000EUP03	EXTENSION MAINS LEAD	1 240	P		0.28	P	S >9.90 P	S <0.05 P	<0.30 P	S
21/11/1915	00000EUP04	POWER UNIT PA300B	2 240	P			S	S >9.90 P	S <0.05 P	<0.30 P	S
21/11/1915	00000EUP05	POWER UNIT MX6-UK-01	2 240	P			S	S >9.90 P	S <0.05 P	<0.30 P	S
21/11/1915	00000EUP06	POWER UNIT PA5D	2 240	P			S	S >9.90 P	S <0.05 P	<0.30 P	S

(P-Pass, S-Skip, F-Fail)

CONTRACTOR DETAILS

Name	TGR Services	
Address	RED ROOFS ROAD CROWHURST LINGFIELD	Enrolment Details
		B. DAVIES BA BSC HONS
Signed		Date
		25th November 2015